



Aiken Electric Cooperative, Inc.  
PO Box 417 – 2790 Wagener Rd  
Aiken, South Carolina 29802-0417  
(803) 649-6245 – Fax (803) 641-8310

## Temporary Underground Service Installation

1. Meter location must be approved by Aiken Electric Co-op
2. All wiring shall be in accordance with the latest edition of the N.E.C., N.E.C.S. and any local government agency having jurisdiction
3. Minimum size conduit 2 ½ inches
4. Minimum of two Grounding Electrode Conductors per code

